

527 CMR 27.00: EMERGENCY AND STANDBY POWER SYSTEMS

Section

27.01: Purpose and Scope

27.02: Adoption by Reference

27.03: Modifications of Provisions of NFPA 110

27.01: Scope and Purpose

___The purpose of 527 CMR 27.00 is to provide performance requirements for the installation, maintenance, operation, and testing of emergency power supply systems.

27.02: Adoption by Reference

___For the purposes of 527 CMR 27.00, the provisions of NFPA standard No. 110, Emergency and Standby Power Systems, 1999 Edition, are incorporated by reference except for the modifications stated in 527 CMR 27.03

27.03: Modification of Provisions of NFPA 110

___For the purpose of 527 CMR 27.00, the provisions of NFPA 110 shall be modified as follows:

(1) Section 2-1 Definitions: The definition of Authority Having Jurisdiction shall be revised to read:

Authority Having Jurisdiction: The head of the fire Department.

Should: For the purposes of 527 CMR 27.00, it is to indicate "shall".

REGULATORY AUTHORITY

527 CMR 27.00: MGL c. 148, §§ 10 and 28.

NON-TEXT PAGE